

**CITY OF ASHEBORO
SYSTEM PERFORMANCE REPORT
JANUARY 1, 2003 – DECEMBER 31, 2003**

THIS REPORT IS COMPILED AND SUBMITTED IN ACCORDANCE
WITH HOUSE BILL 1160 – CLEAN WATER ACT OF 1999.

CITY OF ASHEBORO
DIVISION OF WATER RESOURCES
WASTEWATER TREATMENT DEPARTMENT
POST OFFICE BOX 1106
ASHEBORO, NORTH CAROLINA 27204-1106

CONTACT PERSON:
MR. JOHN OGBURN, CITY MANAGER
POST OFFICE BOX 1106
ASHEBORO, NORTH CAROLINA 27204-1106
PHONE: (336) 626-1200

WASTEWATER PLANT OPERATOR IN
RESPONSIBLE CHARGE:
MR. ARNOLD E. ALLRED
PHONE: (336) 672-0892

SYSTEMS MAINTENANCE OPERATOR IN
RESPONSIBLE CHARGE:
MR. GARY WAYNE AUMAN
PHONE: (336) 873-8626

WATER/SEWER MAINTENANCE OPERATOR
IN RESPONSIBLE CHARGE:
MR. STEVE WOOD
PHONE: (336) 62509352

ASSISTANT WATER/SEWER MAINTENANCE
OPERATOR IN RESPONSIBLE CHARGE:
MR. MARK DAWALT
PHONE: (336) 626-1234, EXT. 2201

APPLICABLE PERMITS:

NPDES PERMIT NO. NC0026123
WASTEWATER COLLECTION SYSTEM PERMIT NO. WQCS00025

COLLECTION SYSTEM PROCESS:

GRAVITY COLLECTION SYSTEM – 195 MILES

**CITY OF ASHEBORO ANNUAL
SYSTEM PERFORMANCE REPORT
PAGE -2-**

LIFT STATIONS: 15

TREATMENT PLANT SYSTEM:

INCLUDES: PRELIMINARY TREATMENT, PRIMARY TREATMENT, BIOLOGICAL TRICKLING FILTERS, SECONDARY TREATMENT, NITRIFICATION AERATION, FINAL CLARIFIERS, SAND FILTERS, CHLORINATION DISINFECTION AND DECHLORINATION.

TREATMENT PLANT PERFORMANCE

DURING THE TWELVE-MONTH PERIOD FROM JANUARY 1, 2003 THROUGH DECEMBER 31, 2003, TOTAL FLOW FOR THE WASTEWATER TREATMENT PLANT WAS 2,055,512,000 GALLONS.

DURING THE PERIOD FROM JANUARY 1, 2003 THROUGH DECEMBER 31, 2003 THE CITY OF ASHEBORO EXPERIENCED TWENTY-SEVEN (27) OVERFLOW EVENTS FROM THE LIFT STATIONS AND FOUR (4) OVERFLOW EVENTS FROM THE COLLECTION SYSTEM. THIS AMOUNTED TO A TOTAL OF 2,154,500 GALLONS OF WASTERWATER OVERFLOWING FROM LIFT STATIONS AND MANHOLES, WHICH REPRESENTS ONLY 0.01 PERCENT OF THE TOTAL FLOW TREATED FOR THIS CALENDAR YEAR. THERE WERE NO PERMIT VIOLATIONS DURING THIS TWELVE-MONTH REPORTING PERIOD.

LIFT STATIONS/TREATMENT PLANT:

JAN. 1, 2003	64,000 GALLONS	LIFT STATION #2 - E. DIXIE DRIVE
JAN. 22, 2003	235,000 GALLONS	LIFT STATION #2 - E. DIXIE DRIVE
JAN. 27, 2003	51,000 GALLONS	LIFT STATION #2 - E. DIXIE DRIVE
MAR. 6, 2003	96,000 GALLONS	LIFT STATION #2 - E. DIXIE DRIVE
MAR. 20, 2003	600,000 GALLONS	LIFT STATION #2 - E. DIXIE DRIVE
MAR. 20, 2003	69,000 GALLONS	LIFT STATION #3 - E. MINE ST. ST.
MAR. 20, 2003	12,000 GALLONS	LIFT STATION #4 - LEXINGTON ROAD
APRIL 7, 2003	83,000 GALLONS	LIFT STATION #2 - E. DIXIE DRIVE
APRIL 9, 2003	82,000 GALLONS	LIFT STATION #2 - E. DIXIE DRIVE
APRIL 10, 2003	154,000 GALLONS	LIFT STATION #2 - E. DIXIE DRIVE

**CITY OF ASHEBORO ANNUAL
SYSTEM PERFORMANCE REPORT
PAGE -3-**

APRIL 10, 2003	17,000 GALLONS	LIFT STATION #4 - LEXINGTON ROAD
APRIL 10, 2003	23,000 GALLONS	LIFT STATION #3 - E. MINE STREET
MAY 22, 2003	90,000 GALLONS	LIFT STATION #2 - E. DIXIE DRIVE
MAY 25, 2003	81,000 GALLONS	LIFT STATION #2 - E. DIXIE DRIVE
JUNE 7, 2003	20,000 GALLONS	LIFT STATION #4 - LEXINGTON ROAD
JULY 7, 2003	115,000 GALLONS	LIFT STATION #2 - E. DIXIE DRIVE
JULY 7, 2003	48,000 GALLONS	LIFT STATION #3 - E. MINE STREET
AUG. 1, 2003	4,500 GALLONS	LIFT STATION #3 - E. DIXIE DRIVE
AUG. 1, 2003	24,000 GALLONS	LIFT STATION #2 - E. DIXIE DRIVE
AUG. 5, 2003	24,000 GALLONS	LIFT STATION #2 - E. DIXIE DRIVE
AUG. 5, 2003	4,000 GALLONS	LIFT STATION #3 - E. MINE STREET
AUG. 10, 2003	11,000 GALLONS	LIFT STATION #4 - LEXINGTON ROAD
AUG. 10, 2003	16,000 GALLONS	LIFT STATION #3 - E. MINE STREET
AUG. 10, 2003	63,000 GALLONS	LIFT STATION #2 - E. DIXIE DRIVE
SEPT. 18, 2003	45,000 GALLONS	LIFT STATION #2 - E. DIXIE DRIVE
SEPT. 18, 2003	12,000 GALLONS	LIFT STATION #3 - E. MINE STREET
SEPT. 22, 2003	55,000 GALLONS	LIFT STATION #2 - E. DIXIE DRIVE

**COLLECTION SYSTEM: (ALL THE FOLLOWING OVERFLOW EVENTS WERE FROM
MANHOLES)**

FEB. 24, 2003	10,000 GALLONS	IN FIELD NEAR YMCA ON NC HIGHWAY 42
APRIL 3, 2003	500 GALLONS	551 NC HIGHWAY 42
OCT. 30, 2003	500 GALLONS	AT ASHEBORO CITY GOLF COURSE BESIDE FAIRWAY #4

**CITY OF ASHEBORO ANNUAL
SYSTEM PERFORMANCE REPORT**

PAGE -4-

NOV. 25, 2003

4,500 GALLONS

IN FIELD AT THE END OF 403
W. BALFOUR AVENUE

CITY OF ASHEBORO DRINKING WATER WAS NOT AFFECTED BY ANY OF THE REPORTED OVERFLOW EVENTS.

NECESSARY MEASURES WERE TAKEN BY BOTH WATER/SEWER MAINTENANCE AND SYSTEMS MAINTENANCE TO ADDRESS, CORRECT AND MINIMIZE THESE OVERFLOW EVENTS. THE DIVISION OF WATER QUALITY IN WINSTON-SALEM WAS NOTIFIED OF EACH OF THESE OVERFLOW EVENTS.

NOTIFICATION: THIS REPORT IS AVAILABLE TO THE PUBLIC AND CAN BE REVIEWED BY CALLING (336) 626-1234, EXT. 2210 TO MAKE AN APPOINTMENT.

NOTIFICATION OF THE AVAILABILITY OF THIS REPORT WILL BE PRINTED ON ALL WATER BILLS MAILED TO CITY OF ASHEBORO WATER CUSTOMERS AT THE NEXT BILLING CYCLE. THIS REPORT WILL BE AVAILABLE ON THE CITY OF ASHEBORO WEB SITE AT CI.ASHEBORO.NC.US.

PUBLIC NOTICE OF THIS REPORT WAS PUBLISHED IN THE COURIER-TRIBUNE ON JANUARY 20, 2004. COPY OF NOTICE IS ATTACHED.

CERTIFICATION:

THIS IS TO CERTIFY THAT THE INFORMATION CONTAINED HEREIN IN THIS REPORT IS TRUE AND ACCURATE TO THE BEST OF MY KNOWLEDGE.

SIGNED: _____ DATE: _____
(DIRECTOR OF WATER RESOURCES)