



**CITY OF ASHEBORO
SYSTEM PERFORMANCE REPORT
JANUARY 1, 2017 - DECEMBER 31, 2017**

THIS REPORT IS COMPILED AND SUBMITTED IN ACCORDANCE
WITH HOUSE BILL 1160 – CLEAN WATER ACT OF 1999.

CITY OF ASHEBORO
DIVISION OF WATER RESOURCES
WASTEWATER TREATMENT DEPARTMENT
POST OFFICE BOX 1106
ASHEBORO, NORTH CAROLINA 27204-1106

Contact Person:

Mr. John Ogburn, City Manager
Post Office Box 1106
Asheboro, North Carolina 27204-1106
Phone: (336) 626-1200

Wastewater Treatment Plant

Operator In Responsible Charge:
Mr. Michael Ray Wiseman
Phone: (336) 672-0892, Ext. 211

Systems Maintenance

Operator In Responsible Charge:
Mr. Jeffrey Dean Cagle
Phone: (336) 672-0892, Ext, 205

Water/Sewer Maintenance Superintendent

Operator In Responsible Charge:
Mr. Andrew Connor
Phone: (336) 626-1234, Ext. 2201

Assistant Water/Sewer Maintenance Superintendent

Back up ORC:
Mr. David Johnson
Phone: (336) 626-1234, Ext. 2205

Mailing Address:
PO Box 1106
Asheboro, NC 27204

Phone: 336-626-1201
Fax: 336-626-1218
www.asheboronc.gov

Physical Address:
146 North Church Street
Asheboro, NC 27203

**CITY OF ASHEBORO ANNUAL
SYSTEM PERFORMANCE REPORT
PAGE -2-**

Water/Sewer Maintenance
Back up ORC:
Mr. Louis Bivins
Phone: (336) 301-5198

Public Works Director
Operator In Responsible Charge:
Mr. David Hutchins
Phone: (336) 626-1234, Ext. 2202

APPLICABLE PERMITS:

NPDES Permit No. NC0026123
Wastewater Collection System Permit No. WQCS00025

COLLECTION SYSTEM PROCESS:

Gravity Collection System – 208.4 Miles
Force Main – 27.2 Miles

LIFT STATIONS: 27

TREATMENT PLANT SYSTEM:

Includes: Preliminary treatment, primary treatment, biological trickling filters, secondary treatment, nitrification aeration, final clarification, sand filters, chlorination, disinfection and dechlorination.

TREATMENT PLANT PERFORMANCE

During the twelve-month period from January 1, 2017 through December 31, 2017, total flow for the wastewater treatment plant was 1,251,110,000 gallons.

During the period from January 1, 2017 through December 31, 2017, the City of Asheboro experienced zero (0) overflow events at the Wastewater Treatment Plant, three (3) overflow events from lift stations and nine (9) overflow events from the collection system. This amounted to a total of 0 gallons from the wastewater treatment plant, 19,975 gallons from lift stations, and 33,280 gallons overflowing from manholes, which represents only 0.004 percent of the total flow treated for this calendar year.

**CITY OF ASHEBORO ANNUAL
SYSTEM PERFORMANCE REPORT
PAGE -3-**

WASTEWATER TREATMENT PLANT

0

LIFT STATIONS:

March 1, 2017	9,550 Gallons	Lift Station #3 – 1129 E. Mine Street - NOV
June 6, 2017	900 Gallons	Lift Station #1 – 1592 Sunset Ave. Ext. - NOV
September 1, 2017	9,525 Gallons	Lift Station #3 – 1129 E. Mine Street - NOV

COLLECTION SYSTEM: (ALL THE FOLLOWING OVERFLOW EVENTS WERE FROM MANHOLES)

January 2, 2017	2,200 Gallons	1632 Ferrari Drive - NOV
March 1, 2017	20,000 Gallons	1759 Fairway Rd/ Force Main near LS #3 – NOV
March 14, 2017	850 Gallons	343 NC Hwy 42 - NOV
March 26, 2017	2,200 Gallons	Sky Drive & West Bailey Street – NOV
April 6, 2017	2,500 Gallons	420 Brewer Street – NOV
April 27, 2017	90 Gallons	504 Worth Street - NOV
May 25, 2017	3,000 Gallons	849 Sherwood Road – NOV
September 1, 2017	2,000 Gallons	928 South Fayetteville Street – NOV
October 26, 2017	440 Gallons	Haskett Creek Outfall – NOV

City of Asheboro drinking water was not affected by any of these overflow events. Necessary measures were taken by both Water/Sewer Maintenance and Systems Maintenance personnel to address, correct, and minimize these overflow events. The Division of Water Resources in Winston-Salem was notified of each of these overflow events.

**CITY OF ASHEBORO ANNUAL
SYSTEM PERFORMANCE REPORT
PAGE -4-**

NOTIFICATION: This report is available to the public and can be reviewed by calling (336) 626-1201, ext. 258 to make an appointment. This report can also be reviewed on the city's website at www.ci.asheboro.nc.us.

Public Notice of this report was published in The Courier-Tribune on Wednesday, February 14, 2018.

CERTIFICATION:

This is to certify that the information contained herein in this report is true and accurate to the best of my knowledge.

Signed: Michael D Rhoney Date: 2/12/18
(Water Resources Director)