



**CITY OF ASHEBORO  
SYSTEM PERFORMANCE REPORT  
JANUARY 1, 2018 - DECEMBER 31, 2018**

THIS REPORT IS COMPILED AND SUBMITTED IN ACCORDANCE  
WITH HOUSE BILL 1160 – CLEAN WATER ACT OF 1999.

CITY OF ASHEBORO  
DIVISION OF WATER RESOURCES  
WASTEWATER TREATMENT DEPARTMENT  
POST OFFICE BOX 1106  
ASHEBORO, NORTH CAROLINA 27204-1106

**Contact Person:**

Mr. John Ogburn, City Manager  
Post Office Box 1106  
Asheboro, North Carolina 27204-1106  
Phone: (336) 626-1200

Wastewater Treatment Plant  
Operator In Responsible Charge:  
Mr. Michael Ray Wiseman  
Phone: (336) 672-0892, Ext. 211

Systems Maintenance  
Operator In Responsible Charge:  
Mr. Jeffrey Dean Cagle  
Phone: (336) 672-0892, Ext, 205

Water/Sewer Maintenance Superintendent  
Operator In Responsible Charge:  
Mr. Andrew Connor  
Phone: (336) 626-1234, Ext. 2201

Assistant Water/Sewer Maintenance Superintendent  
Back up ORC:  
Mr. Shannon White  
Phone: (336) 626-1234, Ext. 2205

Mailing Address:  
PO Box 1106  
Asheboro, NC 27204

Phone: 336-626-1201  
Fax: 336-626-1218  
[www.asheboronc.gov](http://www.asheboronc.gov)

Physical Address:  
146 North Church Street  
Asheboro, NC 27203

**2018 CITY OF ASHEBORO ANNUAL  
SYSTEM PERFORMANCE REPORT  
PAGE – 2**

Water/Sewer Maintenance  
Back up ORC:  
Mr. Louis Bivins  
Phone: (336) 301-5198

Public Works Director  
Operator In Responsible Charge:  
Mr. David Hutchins  
Phone: (336) 626-1234, Ext. 2202

**APPLICABLE PERMITS:**

NPDES Permit No. NC0026123

Wastewater Collection System Permit No. WQCS00025

**COLLECTION SYSTEM PROCESS:**

Gravity Collection System – 205.8 Miles  
Force Main – 28.5 Miles  
Low Pressure – 1.1 Miles

**LIFT STATIONS: 27**

**TREATMENT PLANT SYSTEM:**

Includes: Preliminary treatment, primary treatment, biological trickling filters, secondary treatment, nitrification aeration, final clarification, sand filters, chlorination, disinfection and dechlorination.

**TREATMENT PLANT PERFORMANCE**

During the twelve-month period from January 1, 2018 through December 31, 2018, total flow for the wastewater treatment plant was 1,523,359,000 gallons.

During the period from January 1, 2018 through December 31, 2018, the City of Asheboro experienced zero (0) overflow events at the Wastewater Treatment Plant, twenty-eight (28) overflow events from lift stations and twelve (12) overflow events from the collection system. This amounted to a total of 0 gallons from the wastewater treatment plant, 499,958 gallons from lift stations, and 2,059,760 gallons overflowing from manholes, which represents less than 0.02 percent of the total flow treated for this calendar year.

**WASTEWATER TREATMENT PLANT**

0

**2018 CITY OF ASHEBORO ANNUAL  
SYSTEM PERFORMANCE REPORT  
PAGE – 3**

**LIFT STATIONS:**

August 7, 2018	850 Gallons	Lift Station #1 - 1592 Sunset Avenue - NOV
September 16, 2018	56,100 Gallons	Lift Station #3 - 1129 E. Mine Street – NOV
September 16, 2018	31,000 Gallons	Lift Station #4 - 577 Lexington Road – NOV
September 16, 2018	64,250 Gallons	Lift Station #6 - 15 Richland Place – NOV
September 16, 2018	10,360 Gallons	Lift Station #9 - 1985 Woodell Country Rd - NOV
September 16, 2018	7,200 Gallons	Lift Station #10 -1504 Ferrari Drive – NOV
September 16, 2018	100 Gallons	Lift Station #14- 4404 Hwy 220 Bus. S.
September 27, 2018	1,600 Gallons	Lift Station #4 - 577 Lexington Road
October 11, 2018	14,320 Gallons	Lift Station #1 - 1592 Sunset Avenue
October 11, 2018	16,650 Gallons	Lift Station #3 - 1129 E. Mine Street
October 11, 2018	1,350 Gallons	Lift Station #4 - 577 Lexington Road
October 11, 2018	4,600 Gallons	Lift Station #6 - 15 Richland Place
November 5, 2018	53,600 Gallons	Lift Station #3 - 1129 E. Mine Street - Action Pending
November 5, 2018	15,050 Gallons	Lift Station #4 - 577 Lexington Road – Action Pending
November 5, 2018	21,200 Gallons	Lift Station #6 - 15 Richland Place – Action Pending
November 12, 2018	24,500 Gallons	Lift Station #3 - 1129 E. Mine Street – Action Pending
November 12, 2018	13,925 Gallons	Lift Station #4 - 577 Lexington Road – Action Pending
November 12, 2018	66,093 Gallons	Lift Station #6 - 15 Richland Place – Action Pending
November 15, 2018	10,960 Gallons	Lift Station #3 - 1129 E. Mine Street – Action Pending
November 15, 2018	8,800 Gallons	Lift Station #4 - 577 Lexington Road – Action Pending
November 23, 2018	1,300 Gallons	Lift Station #1 - 1592 Sunset Avenue – Action Pending
November 25, 2018	12,190 Gallons	Lift Station #27 - 3559 Old Cedar Falls Rd - Action Pending
December 20, 2018	14,500 Gallons	Lift Station #3 – 1129 E. Mine Street – Action Pending
December 20, 2018	14,040 Gallons	Lift Station #4 – 577 Lexington Road – Action Pending
December 20, 2018	14,480 Gallons	Lift Station #6 – 15 Richland Place – Action Pending
December 28, 2018	5,790 Gallons	Lift Station #3 – 1129 E. Mine Street – Action Pending
December 28, 2018	2,850 Gallons	Lift Station #3 – 1129 E. Mine Street – Action Pending
December 28, 2018	12,300 Gallons	Lift Station #6 – 15 Richland Place – Action Pending

**2018 CITY OF ASHEBORO ANNUAL  
SYSTEM PERFORMANCE REPORT  
PAGE – 4**

**COLLECTION SYSTEM: (ALL THE FOLLOWING OVERFLOW EVENTS WERE  
FROM MANHOLES)**

January 16, 2018	250 Gallons	623 West Wainman Avenue
February 21, 2018	3,350 Gallons	600 W. Salisbury Street
February 28, 2018	4,350 Gallons	960 Amity Road - NOV
March 21, 2018	250 Gallons	629 Industrial Park Drive
March 31, 2018	410 Gallons	208 N. Wood Drive
April 9, 2018	2,000 Gallons	1818 Flint Street
April 24, 2018	23,000 Gallons	940 Old Liberty Road - NOV
June 1, 2018	2,000,000 Gallons	520 Sunrise Avenue – NOV/NOI
June 4, 2018	7,500 Gallons	Liberty Street Outfall – NOV/NOI
September 17, 2018	14,000 Gallons	Ridgewood Road & E. Allred Street – NOV
December 9, 2018	4,250 Gallons	1230 N. Fayetteville Street – Action Pending
December 26, 2018	400 Gallons	249 N. Elm Street – Action Pending

City of Asheboro drinking water was not affected by any of these overflow events. Necessary measures were taken by both Water/Sewer Maintenance and Systems Maintenance personnel to address, correct, and minimize these overflow events. The Division of Water Resources in Winston-Salem was notified of each of these overflow events.

**NOTIFICATION:** This report is available to the public and can be reviewed by calling (336) 626-1201, ext. 258 to make an appointment. This report can also be reviewed on the city's website at [www.ci.asheboro.nc.us](http://www.ci.asheboro.nc.us).

Public Notice of this report was published in The Courier-Tribune on Wednesday, February 20, 2019.

**CERTIFICATION:**

This is to certify that the information contained herein in this report is true and accurate to the best of my knowledge.

Signed: \_\_\_\_\_

*Michael D. Rhoney*  
(Water Resources Director)

Date: \_\_\_\_\_

*2/19/19*